

Condition  
 BPM to be Calibrated :  
 SP564

Direction :  
 Horizontal Vertical

Used Components :  
 BPM : SP564  
 Steering : {"SX553",1}  
 from -1.5  
 to .5  
 number 4  
 Q magnet: QD564  
 from -2  
 to 2  
 number 8


next remem. save

GO READ

Display  
 BPM : SP584  
 Steering step : 1

Result  
 When the beam is at the Q center :  
 BPM reading [mm]: -1.6934  
 error [mm]: .01886  
 Last BPM taken into account :  
 SP584  
 rel. curr. thresh. : .7

Fit Chk I Save



Condition  
 BPM to be Calibrated :  
 SP564

Direction :  
 Horizontal Vertical

Used Components :  
 BPM : SP564  
 Steering : {"SY553",1}  
 from -7  
 to 1.5  
 number 4  
 Q magnet: QF564  
 from -2  
 to 2  
 number 8

next remem. save

GO READ

Display  
 BPM : SP584  
 Steering step : 1

Result  
 When the beam is at the Q center :  
 BPM reading [mm]: -.05392  
 error [mm]: .02107  
 Last BPM taken into account :  
 SP584  
 rel. curr. thresh. : .7

Fit Chk I Save

Quad BPM 4 e77-

File Edit Window

SP524	-0.491	0.067	( 0.257)
SP544	-0.560	0.072	( 0.153)
SP564	-0.509	0.107	( 0.262)
SP584	-0.483	0.064	( 0.301)

03/03/2006 07:54:27 Hel

Condition  
BPM to be Calibrated :  
SP484

Direction :  
Horizontal Vertical

Used Components :  
BPM : SP484  
Steering : {{'SX473',1}}  
from  
to  
number  
Q magnet: QD484  
from  
to  
number  
next remem. save

GO READ


Display  
BPM : Steering step :  
SP524 1

Result  
When the beam is at the Q center :  
BPM reading [mm]: -508  
error [mm]: .036E

Last BPM taken into account :  
SP584

rel. curr. thresh. :

Fit Chk I Save



Hard HardHard Hard Hard Hard Copy

File Edit Window

SP524	0.482	0.071	( 0.216)
SP544	0.433	0.041	( 0.237)
SP564	0.413	0.035	( 0.293)
SP584	0.390	0.028	( 0.167)

03/03/2006 08:32:05

Condition  
BPM to be Calibrated :  
SP484

Direction :  
Horizontal Vertical

Used Components :  
BPM : SP484  
Steering : {{'SY473',1}}  
from  
to  
number  
Q magnet: QF484  
from  
to  
number  
next remem. save

GO READ


Display  
BPM : Steering step :  
SP524 1

Result  
When the beam is at the Q center :  
BPM reading [mm]: .41  
error [mm]: .01


Last BPM taken into account :  
SP584

rel. curr. thresh. :

Fit Chk I Save



Hard Hard Hard Hard Hard Hard Copy



Condition  
 BPM to be Calibrated :  
 SP444

Direction :  
 Horizontal  Vertical

Used Components :  
 BPM : SP444  
 Steering : {"SX493",1}  
 from -1  
 to 2  
 number 4  
 Q magnet: QD444  
 from -1  
 to 1  
 number 8

next remem. save


GO READ

Display  
 BPM : SP464  
 Steering step : 1

Result  
 When the beam is at the Q center :  
 BPM reading [mm]: .2162  
 error [mm]: .02307  
 Last BPM taken into account :  
 SP584  
 rel. curr. thresh. : .7

Fit Chk I Save

SP464	-0.022	0.021	( 0.176)
SP484	-0.072	0.018	( 0.260)
SP524	-0.076	0.017	( 0.341)
SP544	-0.112	0.014	( 0.269)
SP564	-0.093	0.014	( 0.200)



Condition  
 BPM to be Calibrated :  
 SP444

Direction :  
 Horizontal  Vertical

Used Components :  
 BPM : SP444  
 Steering : {"SY493",1}  
 from -1.5  
 to 1.5  
 number 4  
 Q magnet: QF444  
 from -1  
 to 1  
 number 8

next remem. save

GO READ


Display  
 BPM : SP464  
 Steering step : 1

Result  
 When the beam is at the Q center :  
 BPM reading [mm]: -0.0829  
 error [mm]: .00728  
 Last BPM taken into account :  
 SP564  
 rel. curr. thresh. : .7

Fit Chk I Save

File Edit Window

SP444	0.042	0.029	( 0.286)
SP464	0.125	0.029	( 0.255)
SP484	0.319	0.133	( 0.356)
SP524	0.194	0.050	( 0.342)
SP544	0.118	0.023	( 0.135)



03/03/2006 06:44:26 Help

Condition  
BPM to be Calibrated : SP424

Direction :  Horizontal  Vertical

Used Components :  
BPM : SP424  
Steering : {{"SX413",1}}  
from : -2  
to : 2  
number : 4  
Q magnet: QD424  
from : -1  
to : 1  
number :

next remem. save

GO READ

Display  
BPM : SP444 Steering step : 1


Result  
When the beam is at the Q center :  
BPM reading [mm]: .10917  
error [mm]: .01451  
Last BPM taken into account : SP544  
rel. curr. thresh. : .7

Fit Chk I Save

Hard Hard Hard Hard Hard Copy

File Edit Window

SP444	0.076	0.022	( 0.167)
SP464	0.066	0.015	( 0.256)
SP484	0.028	0.012	( 0.281)
SP524	0.009	0.010	( 0.297)
SP544	0.019	0.011	( 0.248)



03/03/2006 07:43:28 Help

Condition  
BPM to be Calibrated : SP424

Direction :  Horizontal  Vertical

Used Components :  
BPM : SP424  
Steering : {{"SY413",1}}  
from : -1  
to : 1.5  
number : 4  
Q magnet: QF424  
from : -1  
to : 1  
number :

next remem. save

GO READ


Display  
BPM : SP444 Steering step : 1

Result  
When the beam is at the Q center :  
BPM reading [mm]: .02778  
error [mm]: .00564  
Last BPM taken into account : SP544  
rel. curr. thresh. : .7

Fit Chk I Save

HardHard HardHardHard Main Application Area

SP484	0.258	0.021 ( 0.127)
SP524	0.282	0.025 ( 0.186)
SP544	-2.057	8.644 ( 0.117)
SP564	0.306	0.029 ( 0.240)
SP584	0.297	0.022 ( 0.178)



Condition  
BPM to be Calibrated :  
SP464

Direction :  
Horizontal Vertical

Used Components :  
BPM : SP464  
Steering : {{("SX453",1)}  
from -1  
to 2  
number 4  
Q magnet: QD464  
from -1  
to 1  
number 4

next remem. save

GO READ


Display  
BPM : SP484  
Steering step : 4

Result  
When the beam is at the Q center :  
BPM reading [mm]: .28257  
error [mm]: .01198  
Last BPM taken into account :  
SP584

rel. curr. thresh. : .7

Fit Chk I Save

SP484	0.261	0.029 ( 0.16)
SP524	0.219	0.026 ( 0.31)
SP544	0.225	0.023 ( 0.29)
SP564	0.236	0.018 ( 0.24)
SP584	0.240	0.019 ( 0.10)



Condition  
BPM to be Calibrated :  
SP464

Direction :  
Horizontal Vertical

Used Components :  
BPM : SP464  
Steering : {{("SY453",1)}  
from -1.5  
to 2  
number 4  
Q magnet: QF464  
from -1  
to 1  
number 4

next remem. save

GO READ

Display  
BPM : SP484  
Steering step : 1

Result  
When the beam is at the Q center :  
BPM reading [mm]: -2.356  
error [mm]: .00975  
Last BPM taken into account :  
SP584


rel. curr. thresh. : .7

Fit Chk I Save

Quad BPM 3 E 79 -

File Edit Window

SP424	-0.075	0.048	( 0.272)
SP444	-0.071	0.029	( 0.237)
SP464	0.022	0.057	( 0.120)
SP484	-0.234	0.094	( 0.358)
SP524	0.005	0.023	( 0.307)




03/03/2006 09:26:09 Help

Condition  
 BPM to be Calibrated : SP384  
 Direction :  Horizontal  Vertical  
 Used Components :  
 BPM : SP384  
 Steering : {{"SX373",1}}  
 from : -2.5  
 to : 1.5  
 number : 4  
 Q magnet: QD384  
 from : -1  
 to : 1  
 number : 8  
 next remem. save  
 GO READ  
 Display  
 BPM : SP424 Steering step : 1  
 Result  
 When the beam is at the Q center :  
 BPM reading [mm]: -0.3318  
 error [mm]: 0.01588  
 Last BPM taken into account : SP524  
 rel. curr. thresh. :  
 Fit Chk I Save

Hard Hard Han Hard Hard Copy

File Edit Window

SP424	0.234	0.051	( 0.261)
SP444	0.259	0.043	( 0.299)
SP464	0.229	0.034	( 0.350)
SP484	0.220	0.030	( 0.365)
SP524	0.187	0.024	( 0.354)



03/03/2006 09:54:33 Help

Condition  
 BPM to be Calibrated : SP384  
 Direction :  Horizontal  Vertical  
 Used Components :  
 BPM : SP384  
 Steering : {{"SY373",1}}  
 from : -2  
 to : 2  
 number : 2  
 Q magnet: QF384  
 from :  
 to :  
 number :  
 next remem. save  
 GO READ  
 Display  
 BPM : SP424 Steering step : 1  
 Result  
 When the beam is at the Q center :  
 BPM reading [mm]: 0.2150  
 error [mm]: 0.0148  
 Last BPM taken into account : SP524  
 rel. curr. thresh. :  
 Fit Chk I Save

Hard Hard Hard Hard Hard Copy

Linac Machine Study 放射線安全チェックシート

Study項目名	J-arc設定エネルギー変更試験		
日時	2006.03.03		
主催者	紙谷 琢哉		
運転モード	KEKB e-		
	最大繰り返し	最大パルス数	パルスあたり電荷量
	5	1	1
スタディの概要	J-arcの設定エネルギーを変更することが容易にできるようにしておくために、磁場変更ソフトの試験、Dispersion測定及びOptics補正の試験、Isochronicity測定のためのストリークカメラテスト、パンチタイミング測定、それに基づくOptics補正の試験エネルギー設定の変更範囲は1.0-1.7GeV。なお、Dispersion測定時やOptics変更後の調整時などでは一時的にJ-arc部でビームを全ロスすることも起りえる。		

使用する電子銃・加速器

機器名	使用の有無	最大許容出力			
		0.02	GeV	1438	nA
A1電子銃	○	パルスあたり許容電荷 [nC/pulse] 287.60			
電子加速器 (A-Cセクター)	○	3	GeV	1250	nA
		パルスあたり許容電荷 [nC/pulse] 250.00			
C7電子銃	×	0.02	GeV	2000	nA
		パルスあたり許容電荷 [nC/pulse] 400.00			
陽電子生成ターゲット	×	5	GeV	1250	nA
		パルスあたり許容電荷 [nC/pulse] 250.00			
電子陽電子加速器 (1-5セクター)	○	10	GeV	625	nA
		パルスあたり許容電荷 [nC/pulse] 125.00			

予想されるビーム損失場所



ビーム損失箇所	使用の有無	ビーム損失設計値			
		3	GeV	50	nA
電子加速器 (A-Cセクター)	○	パルスあたり許容損失電荷 [nC/pulse] 10.00			
JARC Slit	◎	3	GeV	62.5	nA
		パルスあたり許容損失電荷 [nC/pulse] 12.50			
ビームダンブ1 (B sector end.)	×	3	GeV	62.5	nA
		パルスあたり許容損失電荷 [nC/pulse] 12.50			
電子陽電子ターゲット	×	5	GeV	1250	nA
		パルスあたり許容損失電荷 [nC/pulse] 250.00			
電子陽電子加速器 (1-5セクター, 3SY.ECS)	○	10	GeV	25	nA
		パルスあたり許容損失電荷 [nC/pulse] 5.00			
ビームダンブ2 (3SY 0-deg.)	×	10	GeV	625	nA
		パルスあたり許容損失電荷 [nC/pulse] 125.00			
東側ビームラインダンブ	○	10	GeV	62.5	nA
		パルスあたり許容損失電荷 [nC/pulse] 12.50			
PFBTストップパ	×	4	GeV	10	nA
		パルスあたり許容損失電荷 [nC/pulse] 2.00			

運転に関する注意


ビーム調整時に全ロスが予想される場合は繰り返しを5Hz以下として下さい  
beam-onの際1/パンチであることを確認して下さい

! SP-R0-22 断絶データ読みな。






Energy knob から数  
 1.42 値が決まる。



Sokuteichuu...done.



Sokuteichuu...done.